

A Cloud-based Monitoring System for Performance Assessment of Industrial Plants

Riccardo Bacci di Capaci* and Claudio Scali

Department of Civil and Industrial Engineering, University of Pisa,

Largo Lucio Lazzarino 2, 561226, Pisa, Italy

E-mail: riccardo.bacci@unipi.it

Abstract

The paper presents the realization of a control loop performance monitoring system operating in cloud as single unity for a global supervision of data coming from various industrial plants located in different areas. This is a desirable solution for many companies owing to costs of local installations (systems, human resources and their maintenance and upgrading) and is made possible by available Industry 4.0 technologies, even though some aspects are worth of deeper investigation depending on specific industrial realities.

The monitoring system (PCU – Plant Check Up) is described in its basic components and its evolution towards the cloud-based configuration. The whole architecture, as well as the solutions adopted for data acquisition from the field, transmission to the cloud and web app features which allow a full remote monitoring, are illustrated. Technical details about the application on a pilot-scale plant are given and results for significant cases and different types of loop and actuator status are presented.

1 Introduction

The last years are interested by numerous initiatives and fervent activities, both from academia and industry, aimed at illustrating and employing the impressive characteristics and large opportunities

offered by Industry 4.0^{1,2}. To recall all characteristics and possible advantages of the 9 Key Enabling Technologies (KET), from Advanced Manufacturing Solutions to Big Data and Analytics, would be a heavy and useless burden to carry out. It is important to recall that, while a first glance would convince that advantages are mainly for the manufacturing sector,³ indeed all the process industry can naturally catch the benefits expected from a strong and integrated industrial automation⁴. Thus, the adoption of new methodologies and techniques connected with the Industry 4.0 paradigm can surely lead to significant return of investment for entire industrial plants and in many cases represents a forced choice to survive in a more and more competitive world.

Cloud Computing,⁵ one of the KET, proves to be very useful in general for process monitoring, control and optimization purposes, and in particular for control loop performance monitoring/assessment (CLPM/CLPA).⁶ Cloud computing has natural attractive characteristics, being easy accessible, replicable, distributable, and adaptable. Among other practical advantages, this technology guarantees high power of computation, ability to manage big-data storage and analytics, and opportunities for centralized monitoring. Other main features are limited costs and no capital investment, pay-per-use, on-demand usage, elasticity and multitenancy. Nevertheless, cloud-computing has also several typical issues; among others, cybersecurity, reliability, real-time operation, set-up definition, network topology and system architecture are critical aspects.⁷

Cloud computing has resulted in the creation of attractive process-related applications for a large number of purposes, including: data historians, analysis tools, alarm management, asset management, performance management, training simulators, remote diagnostics.⁸ Several challenges and opportunities of feedback control in cloud computing were discussed in a well-established work⁹.

Nowadays, there are a lot of commercial solutions and technologies which allow one to build an industrial process data analytics platform based on Industry 4.0 paradigms, and on cloud computing, in particular. Among others, main vendors are: cloud services providers (Amazon Web Services, Microsoft Azure, Google, Intel, IBM), enterprise solution vendors (as Oracle and PTC), networking companies (like AT&T, Verizon, Cisco) and industrial engineering companies (e.g., Siemens, ABB, AspenTech, Metso, Rockwell Automation, Honeywell, Bosch and General Electric).

Nevertheless, examples of comprehensive implementation of data analytics in the context of In-

dustry 4.0 are not yet so common in the scientific literature. Among the few cases, interesting cloud-based solutions for remote monitoring (and control) have been applied to: automated electric induction motor,¹⁰ machineries of power plant,¹¹ waste-to-energy (WTE) plant.¹²

Regarding CLPM/CLPA, one of the main advantages offered by cloud computing is that centralized systems can be easily implemented, maintained and updated. Data from different industrial sites can be transferred and analyzed in cloud by using a single monitoring system. This solution can be particular attractive when operators have to monitor a large set of similar plants or units, and, consequently, have to face common issues and faults, or when they have to monitor geographically dispersed assets, as in the case of water or energy supply plants.¹³ In these scenarios, a single system can be developed and installed in a cloud server and monitor all the various units simultaneously.

Other advantages of a single centralized system are the use of an unified logic without risky duplications on single systems and a minimal involvement of dedicated personnel. For on-site solutions, phases of implementation, maintenance and updating must be necessarily replicated locally with obvious time consumption for people and resources and with high risk of errors and omissions.

Therefore, it is out of doubt that cloud-based solutions for process monitoring and assessment will populate the next future. Nevertheless, our experience of last 15 years in the area of control engineering, and in CLPM/CLPA, in particular, leads us to point out that this process of remotization and centralization may be hard. A real difficulty lies in transferring skills developed over years by operators on individual plants. For example, specific knowledge of processes and equipment cannot be fully generalized and therefore cannot be exported in completely automatic manner. In addition, it is to be recalled that process data are usually confidential, and industrial companies may be not persuaded of moving data from local computer control systems to external clouds, as additional issues of cybersecurity and service reliability may arise. Therefore, a strategic decision has to be taken by the companies on economic bases: whole cloud-based service can be performed by a pool of internal experts or can be outsourced to specialized companies.

This work aims to present a novel performance monitoring system, specifically devoted to control loops, based on cloud technology by focusing on three different aspects: describe the whole cloud architecture and its implementation issues, illustrate basic techniques and features installed in the

updated analytics tool, and then present significant cases study.

The paper has then the following structure: Section 2 presents the evolution over time of our system for CLPM from single distributed units to Cloud. Main features of the basic techniques which accomplish performance analysis and malfunction diagnostics are illustrated; a description of the novel cloud-based architecture is also reported. In Section 3, the various functionalities implemented within the web interface for remote management of the system are illustrated. Section 4 describes the pilot plant used to test the whole cloud-based solution, while Section 5 presents some illustrative examples of application. Finally, conclusions and future steps are reported in Section 6.

2 A System for CLPM in Cloud

In the past years, major control engineering companies had proposed their own “traditional”, that is, *on-premises*, software package for control loop performance monitoring and assessment to be installed within local computer control systems of industrial plants. In the literature, several surveys have revised the different commercial solutions.^{6,14} The most recent comparison can be found in,¹⁵ within a work of review on valve stiction. Two examples of software packages from the academia are the smart process data analytics platform¹⁶ from University of Alberta and our *Plant Check-Up* (PCU) system.¹⁷

2.1 The evolution of PCU

The PCU tool is now a long-standing performance monitoring system developed in MATLAB within the Chemical Process Control Laboratory of University of Pisa. The first complete release of the system with extensive industrial implementations was illustrated in.¹⁷ Updated versions with further large-scale applications were then reported in¹⁸ and.¹⁹ A novel release of the system is now developed for the Cloud, as detailed in this paper.

The PCU system is able to diagnose main sources of malfunction of basic single-input single-output (SISO) PID control loops, suggesting actions to be taken. Malfunctions typically induce oscillations in the process variables and therefore their identification is of fundamental importance in

order to carry out the most appropriate correction. Main causes can be traced to the presence of external disturbances, poor controller tuning, faults of valves and sensors, interactions from other loops.²⁰ For these four main malfunctions, actions are upstream intervention, controller retuning, instrument maintenance, transition to multivariable control, respectively.

Until now, depending on measurements available from the field, basic version (PCU) or advanced release (PCU⁺) of the program could be adopted; the latter with significantly higher performance. The variables available from a SISO feedback loop with PID controller are shown in Figure 1.




Figure 1: SISO feedback control loop with variables.

The basic version PCU refers to data made available by traditional industrial plants, that is, only three variables: Set Point (SP), Control Variable (PV) and Controller Output (OP). Such system is installed since many years in ENI refinery sites, monitoring up to dozens of plants and more than 1200 control loops.¹⁷

The later version PCU⁺ has advanced features as it employs additional measurements made available by communication systems based on field bus and smart devices, such as valve position (VP), output pressure (P) of electro-pneumatic (I/P) converter and drive signal (DS) to valve positioner, as well as safety and state parameters of instruments and actuators.¹⁸ Note that the manipulated variable (MV) is typically associated with VP and corresponds to PV in flow rate control loops. The availability of VP allows one to compute TD (Travel Deviation), defined as the difference between actual and desired valve position ($TD = VP - OP$). It has been experimented that, on the basis of different patterns and ranges of TD, friction can be clearly detected and also other causes of malfunction affecting the valve actuator (e.g., air leakage, I/P fault, generic malfunction) can be assessed.¹⁸ Therefore, this advanced version allows a more refined assessment of loops and actuators and is now installed in several Italian power plants (of property ENEL) and has been distributed among associates of Automation and Instrumentation Italian End-Users Club (CLUI AS) for testing purposes.

In the wake of the digital revolution of Industry 4.0, a control loop performance monitoring/assessment system based on cloud technology is here presented. The analysis modules implemented into the on-premises versions of the system are now appropriately updated and inserted in a novel analytics tool (PCU-Cloud) within a cloud-based platform, as detailed in the next two subsections. The novel system is then put at service for multiple industrial plants, of the same or different sites, through the transfer of data in the Cloud and their analysis by a single supervision unit.

2.2 The Analytics Tool

A brief synthesis of the various analysis modules implemented in PCU-Cloud is reported below. Figure 2 shows the whole flow diagram of the novel package of analysis operating in cloud. The main updates with respect to the previous releases of the tool regard the initialization module (IM) and the loop anomaly identification module (Loop_AIM). For a more detailed description of the unchanged modules, the reader can refer to,¹⁷ where the first version of the on-premises system (PCU) was presented.

Initialization Module. This first module (IM) receives data imported from the field, loop parameters and additional information. When not specifically defined, most parameters are set to default values. This module performs several preliminary checks: if the quality of input data is overall bad or the control valve is permanently operating in manual mode, the loop receives a definitive label (NA: Not Analyzed) and the analysis does not proceed further. Whether significant empties in data are detected, as the transmission from field to cloud has accidentally interrupted, the system provides to cut input data file into corresponding sub-files. Something similar occurs when a change of control configuration (manual, automatic, cascade) is registered, so that segments in manual mode are discarded. Finally, the performance assessment can begin. Note that loop path is activated subsequently to actuator path when the travel deviation (TD), that is, valve position error is available, otherwise only loop status is evaluated.

Loop Anomaly Identification Module. This module (Loop_AIM) gives a first assessment of the loop status with diagnostics verdicts. Preliminary, the presence of valve saturation and significant




Figure 2: Flow diagram of the updated analysis package within PCU-Cloud.

changes of Set Point (SP) in terms of amplitude and frequency are investigated. If saturation is detected, after a brief frequency test, a label B (Bad) is assigned. Otherwise, techniques to detect sluggish (SDT) and oscillating (ODT) loops are performed. Slow responses are evaluated by a modified version of the standard technique of Hägglund.²¹ Whereas, oscillating responses are detected by a recently improved sub-module, specifically implemented in this novel version of the tool. Now six different techniques are adopted:

- Hägglund method²² with suitable modifications of internal parameters, based on field experience and plant calibration,¹⁷ to assess magnitude of oscillation;
- two indices (E_{PV} , E_{SP}) based on simple norms of the control error ($e = SP - PV$), to further evaluate magnitude;²³
- Regularity Factor r ²⁴ and Decay Ratio R ²⁵ of autocorrelation function (ACF) of the control error to test regularity and stability of oscillation, respectively;
- a revised version of the method based on empirical mode decomposition (EMD)²⁶ to detect multiple sources of oscillation.²⁷

Each detection technique evaluates a specific oscillation characteristic on the basis of three levels: Good (G), Alert (A), Bad (B), as shown in Figure 2. Then a global verdict on loop oscillation and sluggishness, positive (P) or negative (N), is emitted by weighting single responses.

Identification & Retuning Module. This section (I&R) accounts for process identification and, whether successful, controller retuning and assessment of performance improvements. Loops labeled by Loop_AIM and FAM modules as Bad due to improper tuning, as slow or aggressive, are sent to I&R. Loops with constant and variable Set Point are analyzed differently, by simplex (SPX) and linear least-squares (LLS) method, respectively.²⁸ Note that the second scenario is typical of secondary loops under cascade control.²⁹

Frequency Analysis Module. This module (FAM) aims of separating irregular and regular oscillations on the basis of a power spectrum which computes dominant frequencies. Loops with similar frequency of oscillation can be gathered to investigate possible presence of interactions. Irregular

loops are labeled as Disturbance (with Status Alert or Bad, depending on Loop_AIM), without any further analysis whether TD is not available. Note that these loops are not simply affected by field noise, being otherwise filtered and considered as Good by oscillation detection techniques. Regular loops, if with damped response, are sent to the I&R Module. Otherwise, when loops shows stable oscillations, module for valve stiction vs. disturbance detection (SAM) can be activated.

Stiction Analysis Module. When TD is not available, only on the basis of controller output (OP) and process variable (PV) data, four well-established techniques for valve stiction detection are applied: the relay-based fitting of PV data,³⁰ the improved qualitative shape analysis,³¹ the Cross-Correlation test,³² the Bicoherence method³³ which detects non-linearity in loop data. A global verdict is emitted by weighting the single results. Once clearly detected, stiction amount is also quantified. Various methods developed in our laboratory in the last years are used.^{34,35} Once again, an overall response is emitted by weighting single estimates.

Actuator Anomaly Identification Module. When TD is available, actuator path is activated and six key Performance Indices (KPIs, I_1 - I_6) based on simple metrics of TD with low and high thresholds are employed. By using a field tested logic, it is possible to evaluate actuator status (AS) on three levels (Good, Alert, Bad) and then diagnose specific causes of fault (stiction, air leakage or I/P fault, generic malfunction).¹⁸ These verdict are definitive and may alter the corresponding loop status, as represented by the converging arrows in the south-east corner of Figure 2.

2.3 The System Architecture

A description of the whole cloud-based architecture of the novel system for control loop performance monitoring and assessment is reported in this section. As a premise, we recall that the typical structure of a computer control system in industry is formed by three different network layers: distributed control systems (DCS) network at the bottom, process management network (PMN) in the middle, and corporate local area network (LAN) on the top.³⁶ The architectures of traditional on-premises systems for CLPM/CLPA comprise various modules interacting with each other and all physically installed within the local computer control system. The various components belong to one of three

categories in terms of overall functionality, that is, interface, assistant, and application components.³⁶ This is also the case of our two on-premises CLPM systems developed in the past years.

On-premises systems. A first architecture implements PCU as analytics tool (see Figure 3, left). A Scheduling Module (SM) is the core component which leads the various operations: e.g., establishes hierarchy, order and frequency of acquisition. The User Module (UM) allows the operator to configure loops, check the progress status, query the relational SQL database (DB) for viewing and reports. Once activated by UM, SM gives commands to the various Acquisition Modules (AMs) to collect real-time data from OPC servers. Once acquisition is terminated, the SM receives from AMs the data files which are then sent and store into the database. The CIM (Causes Identification Module) program, which includes PCU tool, is run by the Scheduling Module and acts as the analysis application: interviews the database, acquires input data and emits verdicts.

In a second on-premises system, the advanced version of the tool (PCU⁺) is implemented. A similar architecture is employed (Figure 3, right): a Scheduler manages data acquisition and processing operations; real-time data are collected from various OPC servers via different OPC clients running acquisition applications; analysis results with plots and verdicts are managed by Viewer application. Loop configuration is performed by editing an interface of the database.




Figure 3: Two examples of on-premises architecture for CLPM systems: left) with PCU; right) with PCU⁺.

The cloud-based system. Our novel process monitoring system based on cloud technology has a completely different architecture, as shown in Figure 4. No module is indeed on-premises, that is

installed within the computer control system of the various industrial sites under supervision, but all elements reside in a single remote Linux cloud server located in Pisa. Once transmitted via Internet connection, data are then written and stored into the cloud database (DB), which acts as star center of the whole network. A web interface queries the database and allows results visualization, but also many aspects of loops setting and all phases of analysis management. Nevertheless, note that residual routines of configuration may need to be completed within local computer systems, when peculiarities of industrial sites prevent full remotization. The updated analysis package (PCU-Cloud) works as a single executable program activated by a light scheduler module.

The system employs standard features of cloud technology: JSON data format and MQTT protocol. JSON (JavaScript Object Notation) is a data interchange format, now very spread being particularly simple when used on JavaScript. MQTT (Message Queue Telemetry Transport) is the most common and interoperable messaging system for Internet of Things; it is ISO-standard, based on TCP/IP, and holds intrinsic cybersecurity features. With a publish/subscribe structure, MQTT is designed for lightweight machine-to-machine communications and useful for limited band situations. A client/server model is used, where every smart field device acts as client and connects to a remote server, known as a *broker*. Every message is published to an address, known as a *topic*; clients may subscribe to multiple topics, and every client subscribed to a topic receives every message published to the topic.

In our novel centralized cloud system, the MQTT broker can collect all the messages directly published by the various field elements from different industrial sites, regardless the type: DCS, PLC, or even single smart devices, as sensors and actuators (see Figure 4). Therefore, with respect to on-premises architectures, such solution does not require standard acquisition modules. It is to be noted that the same cloud-based architecture can be easily extended by implementing other monitoring applications and corresponding web interfaces. For example, a condition monitoring system to supervise other plant machineries as pumps, compressors and motors, with the objective of preventive and predictive maintenance, can be included by measuring and transmitting specific variables from the field, as vibrations, rotation velocity, temperature, power absorption.

In the case of the pilot plant IdroLab (see Figure 4), a PLC has been programmed to collect all

data of control loops and, protected by local firewall, send data to the cloud by using a defined JSON string, as later detailed in Section 4.




Figure 4: The architecture of the novel system for cloud-based monitoring of different field elements.

In the proposed solution, high levels of cybersecurity are ensured: cloud platform is intrinsically safe as guaranteed by the server provider; communication channel is protected by a three-level security system, based on a secret alias for the broker, and unique username and password to identify various clients. In addition, MQTT protocol security can be improved by easily turning to a MQTTS solution (where S stands for secured), that is, employing a certificate on server side during Transport Layer Security (TLS) handshake, which avoids “man-in-the-middle” issues. Obviously, industrial companies are still in charge of additional safety requisites within their local networks, as firewall, protected ports, etc.

It is to be noted that the proposed platform has been programmed to be totally scalable and industry oriented. For example, no issues actually involve the software side, as core codes are general and can be easily exported to different monitoring applications. When the number of messages published into the cloud becomes high, since numerous sites or large plants with hundreds or thousands of elements have to be monitored, only physical architecture limitations may need to be overcome, by augmenting transmission band, CPU, RAM and so on. Otherwise, during configuration of local client

systems (PLC, DCS or single devices), one may reduce transmission frequency to limit data traffic and then data size to save cloud space.

Here below, some possible future developments for the centralized cloud structure of Figure 4 are briefly discussed. The adoption of fog computing is advisable to build a preliminary layer, close to the plants and the various smart devices, where performing a preliminary step of storage and computation, e.g., for data check and filtration, alarms managements, critical and confidential analysis. Other communication protocols (e.g., Web of Things, with CoAP) may overcome internet drawbacks and increase system scalability and flexibility. In addition, data mining algorithms can be used to manage big-data analytics in the perspective of predictive maintenance. These functionalities will be taken into consideration in next industrial applications, once some problems may arise in their realization or alternative approaches will be considered more efficient.

3 The Web App

The updated analytics tool (PCU-Cloud) for CLPM in Cloud is interfaced with a Java web application. *Spring* as open-source framework and *Eclipse* as environmental tool have been used for the development. Any interested guest reader can get access and manage the application with a reader level once obtained Username and Password. The main functionalities are briefly presented in this section. For deeper information, the reader can ask for the user guide.

The application has a simple, quick and friendly layout. The monitored plants are organized in the home page within a cascade list (Figure 5). Once a plant is selected, the corresponding sections and control loops are shown. Loops can also be filtered and displayed according to plants and sections they belong to. Each loop is displayed inside a box with two colored fields, associated with the last issue of the tool: on the left the Loop Status, on the right the Actuator Status, according to the following symbology: red: Bad status; yellow: Alert; green: Good; blue: Manual Mode; white: None (loop not yet analyzed); gray: Disabled (loop not currently monitored).

Execution Modes. The system allows two different modes of execution: automatic and manual. Automatic mode performs in fact an on-line analysis at predetermined time intervals. Nevertheless,




Figure 5: Web app home page.

control loops can be reanalyzed off-line in manual mode, that is, by setting a user-defined data interval, specifying start and end date/hour.

Results. The outcome of the analysis are presented at various levels.

Trends: temporal plots of loop measurements. A first plot includes set-point (SP) and control variable (PV); a second one shows PID output controller, i.e. desired valve position (OP), and actual position (MV, that is, VP); third plot shows Travel Deviation (TD), that is, valve position error.

Cycles: polar plots of the process and valve. PV(OP) diagram relates the control variable to output controller; a loop with regular and stable oscillation around a fixed set-point shows a well-defined limit cycle, that is, a circular or elliptical path. MV(OP) diagram relates desired and actual valve position; a sticky valve produces non-linear hysteresis limit cycles, i.e., paths with rectangular or parallelogram shape; this allows a clear distinction with respect to a healthy valve which does not show cycles.

Output: main results of the analysis. This represents a selected list of all detailed fields reported in the output file issued by PCU-Cloud. In section 5, three significant examples of application are illustrated.

Users. There are three levels of users with different roles and privileges:

- *Reader:* basic user with very limited possibilities; one can access only automatic mode executions, and then display verdicts, figures (trends and cycles) of the various loops.
- *Configurator:* user with intermediate possibilities; to get access and also manage manual mode

executions, with the possibility to modify the data period to be analyzed. One can configure only loop details (name, description, plant, section, type of control variable), and also insert and configure new loops, but not threshold values for analysis techniques. Finally, one can download a .zip folder with input and output files related to automatic and manual mode executions.

- *Administrator*: user with full possibilities; to access all the functions of configurator and additionally modify configuration parameters of core techniques to run sensitivity analysis. Furthermore, one can manage plants and users. In particular (see tabs at top of Figure 5):
 - in *Plant Management*, add and modify plants and sections to be monitored;
 - in *User Management*, add and modify user profiles and enable/disable the receipt of periodic notification e-mails with results summary;
 - in *Group Management*, associate a user to a group (administrator, configurator or reader level) and to a role, that is, a level for a specific plant or section.

Loop Management. Analysis parameters can be extensively configured within the web app (see Figure 6). *Execution Frequency* set the frequency with which input file in .csv format are generated and consequently the frequency of analysis execution. *Time Interval* sets duration of single acquisitions, that is, data length inside input files. This time range refers only to the last minutes of data between two consecutive execution times. *Maximum empty in data* sets limit value of the time interval between two consecutive data to consider the presence of an interruption in the transmission to cloud and consequently cause a split of the original data file into two sub-acquisitions.

Expert users, with administrator privileges, can also manage all threshold values of the various performance indices of analysis techniques. As already said, such operation is critical and experience and skills are required. Therefore, a single figure who performs calibration for all control loops and plants of one or more sites may be a suitable solution, only possible with a cloud-based monitoring system. Among others, it is possible to set:

- TD_{lim} : acceptable range for Travel Deviation, with default 2% of valve operating range;¹⁸
- SAT_{lim} : limit to assess valve saturation, as percentage of the data length;
- AB_r : ratio between threshold values of Alert and Bad status for oscillation detection techniques;

- a : amplitude of oscillation for computation of IAE_{lim} in Hägglund's ODT;^{17,23}
- lower and upper thresholds for indices E_{SP} and E_{PV} , which specifically depend on loop type according to.²³
- UI : upgrading index, $\in [0, 1]$, to accept controller retuning proposed by the system.¹⁷

First name	Description	Controlled Variable	Section	plant	Frequency Execution	Data Range (minutes)	Status of notifications	PCU runs enabled	Enabled Email Notification	Actions
12FF018	PC su by-pass ramo 2.5'	Pressure	Branch 2.5 *	IdroLab	0 0 / ? * *	60	No BAD status notification in the last 7 days	Yes	Yes	[edit] [delete] [refresh] [lock] [unlock]
12FF052	FC su by-pass ramo 2.5'	flow	Branch 2.5 *	IdroLab	0 0 / ? * *	30	No BAD status notification in the last 7 days	Yes	Yes	[edit] [delete] [refresh] [lock] [unlock]
12FK019	PC su by-pass ramo 1'	Pressure	Branch 1 *	IdroLab	0 0 / ? * *	5	No BAD status notification in the last 7 days	Yes	Yes	[edit] [delete] [refresh] [lock] [unlock]
12FK020	PC su by-pass ramo 1'	Pressure	Branch 1 *	IdroLab	0 0 / 5 / ? * *	5	No BAD status notification in the last 7 days	Yes	Yes	[edit] [delete] [refresh] [lock] [unlock]
12FK057	PC downstream branch 2.5 *	Pressure	Branch 2.5 *	IdroLab	0 0 * / 8 ? * *	360	No BAD status notification in the last 7 days	Yes	No	[edit] [delete] [refresh] [lock] [unlock] [trash]
12FK087	PC downstream branch 1 *	Pressure	Branch 1 *	IdroLab	0 0 * / 2 ? * *	120	No BAD status notification in the last 7 days	No	No	[edit] [delete] [refresh] [lock] [unlock] [trash]

Figure 6: Loop management page.

Statistics. This features allows one to evaluate the overall performance of a plant, a particular section or even a specific control loop along a defined period of time. Two tables with aggregated results can be examined (see Figure 7):

- *States*: total number of different status – Manual, Good, Alert, Bad – for loop and actuator; note that, crossing rows and columns, it is also possible to asses the number of times that a combined verdict occurred.
- *Causes*: besides numbers of healthy actuators and loops, different causes of poor behavior are summarized: e.g., valves in manual, controller issues, valve problems, disturbances, etc.

Periodical and event-based notifications. The application sends periodical notification e-mails with summary performance of the various plants and details of the last verdict for each loop under supervision. Notification frequency and information degree of detail can be customized in order to limit message flooding. In addition, it is possible to enable a class of *critical* loops (key in terms of safety or productivity) for which, as soon as loop or actuator status changes into Bad, a specific e-mail




Figure 7: Statistics page.

is immediately sent and an alarm icon is activated. The company user can acknowledge the alarm and then make suitable corrections.

4 The IdroLab Plant

IdroLab is a pilot plant recently revamped to become a demonstrator facility of Industry 4.0 technologies in the framework of a project developed by (CLUI AS) (see Figure 8). The plant is also proposed for training purposes and demo for users. Recently, a novel PLC (*Siemens, Simatic S7-1500*) has been installed and configured with *Simatic Step7 TIA Portal* program to control operations. The plant is composed by a double hydraulic circuit equipped with a centrifugal pump under inverter control, as shown in Figure 9. A preexisting set of latest generation actuators and sensors allows process operation and variables measurement (pressure, flow rate and level). Fieldbus communication from smart devices to PLC is accomplished with Profibus protocol; communication from PLC to cloud server occurs with MQTT protocol, as detailed in Section 2.3.

Five PID control loops are programmed into the PLC; their features and parameters are listed in Table 1. PLC operates each loop with a sampling time of 1 s, collects and stores data in its local DB, and then sends data to the cloud server. The various data are written within a defined string in JSON format with key and value notation. At each time sampling, the JSON string includes the following



Figure 8: The IdroLab pilot plant.




Figure 9: Synoptic of IdroLab on Human Machine Interface of PLC.

fields: name, time stamp, loop measurements – SP, PV, OP, as mandatory, MV (that is, VP), DS, P, as optional, and controller parameters – proportional gain (pidP), integral constant (pidI), derivative constant (pidD), filter constant (pidF), controller mode (pidmode), high and low limit on OP (pidOL, pidOH) and PV (PVL, PVH).

Main causes of malfunction can be reproduced by means of some physical modular items as described in.³⁷ In addition, faults can be also introduced by the use of dedicated software blocks.

Valve stiction is reproduced by implementing a data-driven model within a customized function block of the PLC (see Figure 9). Valve stiction dynamics is indeed modeled as follows:

$$MV_k = \begin{cases} M(OP_k - f_D) + MV_{k-1}(1 - M) & \text{if } OP_k - MV_{k-1} > f_S \\ M(OP_k + f_D) + MV_{k-1}(1 - M) & \text{if } OP_k - MV_{k-1} < -f_S \\ MV_{k-1} & \text{if } |OP_k - MV_{k-1}| \leq f_S \end{cases} \quad (1)$$

where f_S and f_D are static and dynamic friction parameters, respectively. Note that both standard³⁸ and semiphysical version³⁹ of the well-established He's stiction model can be reproduced, by setting $M = 1$ or $M = 1.99$, respectively. Recalling that parameters of He's model have their theoretically equivalent in Kano's model,⁴⁰ user has to set stick-band plus dead-band $S = f_S + f_D$ and slip-jump $J = f_S - f_D$, so that, $f_S = \frac{S+J}{2}$ and $f_D = \frac{S-J}{2}$. Note that one can also select which signal is recycled as input into the block: the block output (MV) or the actual valve position (POS). In this second case, valve dynamics is mixed with simulated stiction nonlinearity, so that typical wave forms of friction may be altered.⁴¹

Moreover, external software disturbances are introduced within the inverter and two motored valves. A sinusoidal disturbance can be added to the desired inverter velocity. One can set amplitude and frequency of oscillation around the set-point value. Whereas, the input signal to motored valve 12FS013 is added with a step-wise wave. Here one can select extremes of oscillation (D_{min} , D_{max}) within 0-100% range, step size Δ and step duration τ (compare the yellow pop-up of Figure 9).

Table 1: Control loops implemented in the IdroLab plant.

Valve (Tag within PCU)	Actuator type	Type of PV	PV range	Sensor
12FK057	pneumatic	pressure	0 ÷ 5 bar	12PT064
12FF018	pneumatic	pressure	0 ÷ 5 bar	12PT063
12FF052	electric	flow rate	0 ÷ 5 L/s	12LP033
12FK020	pneumatic	pressure	0 ÷ 5 bar	12PT122
12FK019	pneumatic	pressure	0 ÷ 5 bar	12PT123

5 Examples of Application

In this section, three examples of application of the analytics tool PCU-Cloud are illustrated. Performance of loop and actuator 12FK020 of the IdroLab pilot plant are below detailed. These cases represent a synthesis of some typical behaviors, but all main types of malfunction have been successfully tested.

Case i) – good loop. This first data set represents a case of good behavior, without any type of malfunction (see Figure 10). Two step changes are imposed to set-point, PID controller has good tuning, and no stiction is introduced into the valve. The PCU-Cloud actually emits a correct verdict of Good status, both on loop and actuator (compare Section 2.2). In details, all six oscillation detection techniques (ODT), assess no fluctuation in PV data (see Table 2). All six key performance indices (KPIs) for actuator status are below their thresholds as TD does not exhibit significant sticky movements and lays within its acceptable range TD_{lim} .

Case ii) – valve stiction. To simulate stiction within valve 12FK020, the dedicated software block is activated. The following parameters are set: $S = 4$, $J = 2$ and the output signal (MV) is recycled back as input (see Figure 9). Typical wave forms – PV and MV squared, OP triangular – are registered, as shown in Figure 11. The cloud-based monitoring system evaluates properly both loop and actuator status. Travel Deviation shows evident stick-slip trend, even outside TD_{lim} , so that the corresponding KPI¹⁸ exceeds its threshold and stiction can be perfectly recognized. Valve malfunction induces also evident oscillations in PV data. The various ODT emit different outcomes, as reported in Table 2. The final averaged verdict of oscillation is Alert (2.5/6) and also loop status is evaluated as Alert.




Figure 10: Time trends for case i) - good behavior.




Figure 11: Time trends for case ii) - valve stiction.

Case iii) – external disturbance. In this example, stable oscillations are induced by adding software disturbance to the set-point velocity of the pump inverter. A sinusoidal disturbance, with relative amplitude $A = 5\%$ and frequency $f = 1/240$ Hz, is inserted, whose effects are particular evident in OP data, as shown by Figure 12. PCU-Cloud emits an appropriate verdict: actuator and loop status are assessed as Good and Alert, respectively. All six KPIs for actuator status are below their thresholds as TD lays within its acceptable range TD_{lim} . The outcomes of various ODT are reported in Table 2. Also in this scenario, the final averaged verdict of oscillation is Alert (2.5/6) and then loop status is evaluated as Alert.




Figure 12: Time trends for case iii) - external disturbance.

Table 2: Verdict of six oscillation detection techniques.

Case	Hägglund	E_{PV}	E_{SP}	r	R	EMD	Final
i)	Good (0)	Good (0)	Good (0)	Good (0)	Good (0)	Good (0)	Good (0/6)
ii)	Good (0)	Good (0)	Alert (0.5)	Good (0)	Bad (1)	Bad (1)	Alert (2.5/6)
iii)	Alert (0.5)	Good (0)	Good (0)	Good (0)	Bad (1)	Bad (1)	Alert (2.5/6)

6 Conclusions

The system illustrated in this paper represents a successful example of cloud-based platform for performance monitoring and assessment of process plants, specifically oriented to PID control loops. The same approach can be easily taken for the global monitoring of plant performance and equipment efficiency. Details of implementation have been illustrated, in terms of global architecture and modules within the analytics tool (PCU-Cloud) of the system, for the specific case of application to a pilot-scale plant.

The system employs today available technologies of Industry 4.0 and can be built with very reasonable investments to complete the required automation and instrumentation, in large part already preexisting in the plant. The additional costs of cloud will be compensated by savings and advantages in the need of an unique monitoring system, with consequent reduction of skills to be developed and resources to be maintained on each single plant. Open issues, as cybersecurity, data traffic and message size, and practical problems, as analysis scheduling and system configuration, must be solved jointly by the industrial firm and the external company. Results of application to several significant control loops, which represent a synthesis of various conditions of good operation and presence of different types of malfunction, confirm the effectiveness of the cloud-based monitoring.

As future step, the same cloud-based architecture will be extended to other functionalities, e.g., condition monitoring purposes to supervise other plant machineries as pumps, compressors and motors with the objective of preventive and predictive maintenance.

Acknowledgement

We are really grateful to our partners in the project “Idrolab 4.0: A Cloud-Based Performance Monitoring Project” within the framework of CLUI AS - Automation and Instrumentation Italian End-Users Club.

References

- (1) Wan, J.; Cai, H.; Zhou, K. Industrie 4.0: Enabling technologies. Proceedings of 2015 International Conference on Intelligent Computing and Internet of Things. 2015; pp 135–140.
- (2) Wang, S.; Wan, J.; Li, D.; Zhang, C. Implementing Smart Factory of Industrie 4.0: An Outlook. *International Journal of Distributed Sensor Networks* **2016**, *12*, 3159805.
- (3) Babiceanu, R. F.; Seker, R. Big Data and virtualization for manufacturing cyber-physical systems: A survey of the current status and future outlook. *Computers in Industry* **2016**, *81*, 128 – 137.
- (4) Bauer, M.; Schlake, J. C. Changes to the automation architecture: Impact of technology on control systems algorithms. 2017 22nd IEEE International Conference on Emerging Technologies and Factory Automation (ETFA). 2017; pp 1–8.
- (5) Mell, P.; Grance, T. The NIST definition of Cloud Computing, 800-145. 2011.
- (6) Jelali, M. An overview of control performance assessment technology and industrial applications. *Control Engineering Practice* **2006**, *14*, 441–466.
- (7) Puthal, D.; Sahoo, B. P. S.; Mishra, S.; Swain, S. Cloud Computing Features, Issues, and Challenges: A Big Picture. 2015 International Conference on Computational Intelligence and Networks. 2015; pp 116–123.
- (8) Latha, D.; Jayaprakash, K. The rise of cloud computing in industrial process automation. <https://www.automation.com/automation-news/article/the-rise-of-cloud-computing-in-industrial-process-automation>, 2017.
- (9) Lim, H. C.; Babu, S.; Chase, J. S.; Parekh, S. S. Automated control in Cloud Computing: Challenges and opportunities. Proceedings of the 1st Workshop on Automated Control for Datacenters and Clouds. New York, NY, USA, 2009; pp 13–18.

- (10) da Silva, A. F.; Ohta, R. L.; dos Santos, M. N.; Binotto, A. P. A Cloud-based Architecture for the Internet of Things targeting Industrial Devices Remote Monitoring and Control. *IFAC-PapersOnLine* **2016**, *49*, 108–113.
- (11) Elazab, E.; Awad, T.; Elgamal, H.; Elsouhily, B. A cloud based condition monitoring system for industrial machinery with application to power plants. Proceedings of the 19th International Middle East Power Systems Conference (MEPCON). 2017; pp 1400–1405.
- (12) Kabugo, J. C.; Jämsä-Jounela, S.-L.; Schiemann, R.; Binder, C. Industry 4.0 based process data analytics platform: A waste-to-energy plant case study. *International Journal of Electrical Power & Energy Systems* **2020**, *115*, 105508.
- (13) McGraw, C. Cloud-based software solutions for industrial applications. <https://www.controleng.com/articles/cloud-based-software-solutions-for-industrial-applications/>, 2018.
- (14) Shardt, Y.; Zhao, Y.; Qi, F.; Lee, K.; Yu, X.; Huang, B.; Shah, S. L. Determining the state of a process control system: Current trends and future challenges. *Can. J. Chem. Eng.* **2012**, *90*, 217–245.
- (15) Bacci di Capaci, R.; Scali, C. Review and comparison of techniques of analysis of valve stiction: From modeling to smart diagnosis. *Chemical Engineering Research and Design* **2018**, *130*, 230–265.
- (16) Hu, W.; Shah, S. L.; Chen, T. Framework for a smart data analytics platform towards process monitoring and alarm management. *Computers & Chemical Engineering* **2018**, *114*, 225 – 244.
- (17) Scali, C.; Farnesi, M. Implementation, parameters calibration and field validation of a closed loop performance monitoring system. *Annual Reviews in Control* **2010**, *34*, 263–276.
- (18) Bacci di Capaci, R.; Scali, C.; Pestonesi, D.; Bartaloni, E. Advanced diagnosis of control loops: Experimentation on pilot plant and validation on industrial scale. Proceedings of 10th IFAC DYCOPS. Mumbai, India, 18–20 December, 2013; pp 589–594.

- (19) Bacci di Capaci, R.; Scali, C. A performance monitoring tool to quantify valve stiction in control loops. Proceedings of the 19th IFAC World Congress. Cape Town, South Africa, 24–29 August, 2014; pp 6710–6716.
- (20) Bauer, M.; Horch, A.; Xie, L.; Jelali, M.; Thornhill, N. The current state of control loop performance monitoring – A survey of application in industry. *Journal of Process Control* **2016**, *38*, 1–10.
- (21) Hägglund, T. Automatic detection of sluggish control loops. *Control Engineering Practice* **1999**, *7*, 1505–1511.
- (22) Hägglund, T. A control-loop performance monitor. *Control Engineering Practice* **1995**, *3*, 1543–1551.
- (23) Scali, C.; Marraccini, S.; Farnesi, M. Key parameters calibration and benefits evaluation of a closed loop performance monitoring system. Proceedings of the 9th IFAC-DYCOPS 2010. Louvain, Belgio, 5–7 July, 2010; pp 683–688.
- (24) Thornhill, N. F.; Huang, B.; Zhang, H. Detection of multiple oscillations in control loops. *Journal of Process Control* **2003**, *13*, 91–100.
- (25) Miao, T.; Seborg, D. Automatic detection of excessively oscillatory feedback control loops. Proceedings of the IEEE International Conference on Control Applications. Kohala Coast, HI, USA, 22–27 August, 1999; pp 359–364.
- (26) Srinivasan, B.; Rengaswamy, R. Automatic oscillation detection and characterization in closed-loop systems. *Control Engineering Practice* **2012**, *20*, 733–746.
- (27) Porro, F. Cloud-based monitoring: Problematiche, architetture, applicazioni a dati di impianto. 2019; Master Thesis.
- (28) Bacci di Capaci, R.; Scali, C. Process control performance evaluation in the case of variable set-point with experimental applications. *The Canadian Journal of Chemical Engineering* **2017**, *95*, 1707–1720.

- (29) Marchetti, E.; Esposito, A.; Scali, C. A refinement of cascade tuning to improve control performance without requiring any additional knowledge on the process. *Industrial & Engineering Chemistry Research* **2013**, *52*, 6193–6200.
- (30) Rossi, M.; Scali, C. A comparison of techniques for automatic detection of stiction: Simulation and application to industrial data. *Journal of Process Control* **2005**, *15*, 505–514.
- (31) Scali, C.; Ghelardoni, C. An improved qualitative shape analysis technique for automatic detection of valve stiction in flow control loops. *Control Engineering Practice* **2008**, *16*, 1501–1508.
- (32) Horch, A. A simple method for detection of stiction in control valves. *Control Engineering Practice* **1999**, *7*, 1221–1231.
- (33) Choudhury, M. A. A. S.; Shah, S. L.; Thornhill, N. F. Diagnosis of poor control loop performance using higher order statistics. *Automatica* **2004**, *40*, 1719–1728.
- (34) Bacci di Capaci, R.; Scali, C. Stiction quantification: A robust methodology for valve monitoring and maintenance scheduling. *Industrial & Engineering Chemistry Research* **2014**, *53*, 7507–7516.
- (35) Bacci di Capaci, R.; Scali, C.; Pannocchia, G. System identification applied to stiction quantification in industrial control loops: A comparative study. *J. Process Contr.* **2016**, *46*, 11–23.
- (36) Lee, K. H.; Tamayo, E. C.; Huang, B. Industrial implementation of controller performance analysis technology. *Control Engineering Practice* **2010**, *18*, 147–158.
- (37) Scali, C.; Matteucci, E.; Pestonesi, D.; Zizzo, A.; Bartaloni, E. Experimental characterization and diagnosis of different problems in control valves. Proceedings of the 18th IFAC World Congress. Milano, Italy, 28 August–2 September, 2011; pp 7334–7339.
- (38) He, Q. P.; Wang, J. Valve stiction quantification method based on a semiphysical valve stiction model. *Industrial & Engineering Chemistry Research* **2014**, *53*, 12010–12022.

- (39) He, Q. P.; Wang, J. Valve stiction modeling: First-principles vs. data-drive approaches. Proceedings of the 7th American Control Conference. Baltimore, MD, USA, 30 June–2 July, 2010; pp 3777–3782.
- (40) Kano, M.; Hiroshi, M.; Kugemoto, H.; Shimizu, K. Practical model and detection algorithm for valve stiction. Proceedings of 7th IFAC DYCOPS. Boston, USA, 5–7 July, 2004; Paper ID n. 54.
- (41) Jelali, M.; Huang, B. *Detection and Diagnosis of Stiction in Control Loops: State of the Art and Advanced Methods*; Springer-Verlag, London, 2010.

Nomenclature

Acronyms

CIM Causes Identification Module

CLPM/CLPA Control Loop Performance Monitoring/Assessment

DCS Distributed Control System

JSON JavaScript Object Notation

KET Key Enabling Technologies

MQTT Message Queue Telemetry Transport

MV Manipulated Variable

OP Controller Output

OPC Open Platform Communications

PV Process Variable

SM Scheduling Module

SP Set Point

TCP/IP Transmission Control Protocol/Internet Protocol

TLS Transport Layer Security

UM User Module

VP Valve Position